

To confirm the validity of the gas operative please contact Gas Safe Register on Tel: 0800 408 5500

Serial No.  
**22768**

# MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY CHECK DUE WITHIN  
**6-12 MONTHS**

This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

**Registered Business Details** REGISTRATION NO 30091  
 Gas operative Paul Bathstini (Print name)  
 Operative licence No 3593406  
 Company Commercial written services  
 Address 16 Lyon Road  
Merton London  
 Postcode SW19 2QJ Tel No. 0208 5432255

**Details of Vehicle**  Trailer  (tick appropriate box)  
 Reg No. or Serial/Chassis No. N/A  
 LPG cylinder housing satisfactory Yes/No NO  
 Fire extinguisher(s) provided Yes/No NO  
 Fire blanket provided Yes/No/NA NO  
 Current safety certificate displayed Yes/No NO  
 Safe use of LPG information displayed Yes/No NO

**Vehicle/Trailer Owner Details**  
 Name (Mr/Mrs/Ms/Ms/Ms) BIG ROAST  
 Address WIMBLEDON  
 Postcode SW19 2QJ Tel No. \_\_\_\_\_  
 No. of appliances tested  1

**APPLIANCE DETAILS**

	Appliance type	Make	Model	Serial No.	Flue type OF/RS/FL	Is appliance secure Yes/No	Is appliance valve fitted
1	HOS. ROAST	N/A	N/A	N/A	OF	Yes	Yes
2							
3							
4							

**INSPECTION DETAILS**

	Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance to use Yes/No
1	N/A	NO	Yes	N/A	N/A	N/A	N/A	Yes	Yes
2									
3									
4									

**DEFECT(S) IDENTIFIED**

1 Old gas hose (use outside beyond only) 2012

2 Subtle clips not crimps

3

4

If Warning/Advice Notice issued insert serial No.\*

**REMEDIAL ACTION TAKEN**

1

2

3

4

Cylinder/final connection hoses to installation satisfactory Yes/No

Gas installation pipework (visual inspection) satisfactory Yes/No

Gas tightness test satisfactory Yes/No/NA

ECV accessible and operable Yes/No

LPG regulator operating pressure (mbar)

LPG regulator lock-up pressure (mbar)

Safety check issued by: Signed Paul Bathstini  
 Print name: Paul Bathstini  
 Received by: Paul Bathstini  
 Date appliance(s)/flue(s) checked: 18th March 2016