

To confirm the validity of the gas operative please contact Gas Safe Register on Tel: 0800 408 5500

Serial No.
22769

MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY
CHECK DUE WITHIN
6-12 MONTHS

This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Registered Business Details REGISTRATION NO 30691
 Gas operative Paul Bathstn (Print name)
 Operative licence No. 3593406
 Company Commercial Kitchen Services
 Address 16 Lyon Rd
Marble London.
 Postcode SW19 2RL Tel No. 0208 5432255

Details of Vehicle Trailer (tick appropriate box)
 Reg No. or Serial/Chassis No. N/A
 LPG cylinder housing satisfactory Yes/No NO
 Fire extinguisher(s) provided Yes/No NO
 Fire blanket provided Yes/No/NA NO
 Current safety certificate displayed Yes/No NO
 Safe use of LPG information displayed Yes/No NO

Vehicle/Trailer Owner Details
 Name Big Hog Rental
 Address Edgeware Way
Uxbridge
 Postcode SW19 8UT Tel No. _____
 No. of appliances tested 1

APPLIANCE DETAILS

Appliance type	Make	Model	Serial No.	Flue type OF/RS/FL...	Is appliance secure Yes/No	Is appliance isolated valve fitted Yes/No
1 Hog Rent	N/A	N/A	N/A	FL	YES	YES
2						
3						
4						

INSPECTION DETAILS

Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1 37m/s	NO	YES	N/A	N/A	N/A	N/A	YES	YES
2								
3								
4								

DEFECT(S) IDENTIFIED

1 Appliance out of Date (2 years only outside) 2012 YES

2 Subbie clips fitted (clamps)

3

4

REMEDIAL ACTION TAKEN

1

2

3

4

REMARKS

Cylinder/final connection hoses to installation satisfactory Yes/No YES
 Gas installation pipework (visual inspection) satisfactory Yes/No N/A
 Gas tightness test satisfactory Yes/No/NA YES
 ECV accessible and operable Yes/No YES
 LPG regulator operating pressure (mbar) 37
 LPG regulator lock-up pressure (mbar) 37

Safety check issued by: signed [Signature]
 Print name: Paul Bathstn
 Received by: [Signature]
 Date appliance(s) checked: 18th March 2016