

To confirm the validity of the gas operative please contact Gas Safe Register on Tel: 0800 408 5500

Serial No.
22770

MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY CHECK DUE WITHIN
6-12 MONTHS

This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Registered Business Details REGISTRATION NO **30091**
 Gas operative **Paul Bathstini** (Print name)
 Operative licence No **3593406**
 Company **Commercial Kitchen Services**
 Address **16 Lyon Rd**
Merthyr, Abandon
 Postcode **Su19 2AL** Tel No. **0208 5432255**

Details of Vehicle Trailer (tick appropriate box)
 Reg No. or Serial/Chassis No. **N/A**
 LPG cylinder housing satisfactory Yes/No **NO**
 Fire extinguisher(s) provided Yes/No **NO**
 Fire blanket provided Yes/No/NA **NO**
 Current safety certificate displayed Yes/No **NO**
 Safe use of LPG information displayed Yes/No **NO**

Vehicle/Trailer Owner Details
 Name ~~Paul Bathstini~~ **Big Hog Roast**
 Address **Edenmore Way**
Wimborton
 Postcode **Su19 8uh** Tel No. _____
 No. of appliances tested

APPLIANCE DETAILS

Appliance type	Make	Model	Serial No.	Flue type OF/RS/FL	Is appliance secure Yes/No	Is appliance iso valve fitted Yes
1 Hog Roast	N/A	N/A	N/A	FL	yes	yes
2						
3						
4						

INSPECTION DETAILS

Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1 37	NO	yes	N/A	N/A	N/A	N/A	yes	yes
2								
3								
4								

DEFECT(S) IDENTIFIED

1 **Here out of Date (2 years old) expire 2012** If Warning/Advice Notice Issued insert serial No.

2 **Subsae clips (must be carried)**

3

4

REMEDIAL ACTION TAKEN

1 **Leak found repaired on Here**

Cylinder/final connection hoses to installation satisfactory Yes/No

Gas installation pipework (visual inspection) satisfactory Yes/No

Gas tightness test satisfactory Yes/No/NA

ECV accessible and operable Yes/No

LPG regulator operating pressure (mbar)

LPG regulator lock-up pressure (mbar)

Safety check issued by: Signed **P Bathstini**

Print name: **Paul Bathstini**

Received by: _____

Date appliance(s)/flue(s) checked: **18th March 2011**

