

To confirm the validity of the gas operative please contact Gas Safe Register on Tel: 0800 408 5500

Serial No.
227771

MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY
CHECK DUE WITHIN
6-12 MONTHS

This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Registered Business Details REGISTRATION NO 30091
 Gas operative Paul Bathshini (Print name)
 Operative licence No 3593406
 Company Commercial Writtle Services
 Address 16 Lyon Rd
Merton London
 Postcode SW19 6RL Tel No. 0208 543 2255

Details of Vehicle Trailer (tick appropriate box)
 Reg No. or Serial/Chassis No. N/A
 LPG cylinder housing satisfactory Yes/No No
 Fire extinguisher(s) provided Yes/No No
 Fire blanket provided Yes/No/NA No
 Current safety certificate displayed Yes/No No
 Safe use of LPG information displayed Yes/No No

Vehicle/Trailer Owner Details
 Name (M/Ms/Miss/Ms) Big Tony Peters
 Address Erdenover Way
Wimbleton
 Postcode SW19 6UL Tel No. _____
 No. of appliances tested 1

APPLIANCE DETAILS

Appliance type	Make	Model	Serial No.	Flue type OF/RS/EL	Is appliance secure Yes/No	Is appliance safe valve fitted Yes/No
1 <u>Hag roof</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>FL</u>	<u>Yes</u>	<u>Yes</u>
2						
3						
4						

INSPECTION DETAILS

Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1 <u>37</u>	<u>No</u>	<u>Good</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>Yes</u>	<u>Yes</u>
2								
3								
4								

DEFECT(S) IDENTIFIED

1 HOSE OVER TWO YEARS OLD (OUTSIDE)

2 JUBILEE CLIPS (CARIMBS)

3

4

REMEDIAL ACTION TAKEN

1

2

3

4

If Warning/Advice Notice issued insert serial No. 200

Cylinder/final connection hoses to installation satisfactory Yes/No Yes
 Gas installation pipework (visual inspection) satisfactory Yes/No Yes
 Gas tightness test satisfactory Yes/No/NA Yes
 ECV accessible and operable Yes/No Yes
 LPG regulator operating pressure (mbar) 35
 LPG regulator lock-up pressure (mbar) 3

Safety check issued by: P. Bathshini
 Print name: P. Bathshini
 Received by: [Signature]
 Date appliance(s)/flue(s) checked: 18th March 2012